Non-CO₂ Greenhouse Gases: High-GWP Gases

Source/Sectors: Substitution of ODS/Motor Vehicle Air Conditioners

Technology: HFC-152a systems (C.1.1.3.3)

Description of the Technology:

HFC-152a has considerably lower GWP and therefore, is in use as a drop-in replacement for HFC-134a. This option can be used in both direct expansion and secondary loop MVAC systems (USEPA, 2006b). HFC-152a is also available for use in a "low-leak" system, which is expected to further reduce the emission. This option is expected to be in use beginning in 2012 (CEC, 2005).

Effectiveness: It can reduce total emissions by 89% as a result of its lower GWP (CEC, 2005).

Implementability: HFC-152a direct expansion systems in MVACs would not require any significant changes when being shifted from HFC-134a systems except for the safety enforcement such as refrigerant detector systems (USEPA, 2006b).

Reliability: Good

Maturity: The technology is still in the development phase (USEPA, 2006b).

Environmental Benefits: HFCs emission reduction

Cost Effectiveness:

This abatement option is estimated to have a capital cost of approximately \$25/car; there is no available cost related data for the low-leak system (CARB, 2004). It has the lowest capital cost than any other MVAC options (USEPA, 2006b).

Technology	Lifetime (yrs)	MP (%)	RE (%)	TA (%)	Capital cost	Annual cost	Benefits
HFC-152a systems ¹	-	0	89	15	\$192.33	\$0.00	\$54.15

Note: MP: market penetration; RE: reduction efficiency; TA: technical applicability; costs are in year 2000 US\$/MT_{CO2-Eq.} 1: CEC (2005)

Industry Acceptance Level: HFC-152a will have a wide market share in Europe, Australia, and Japan; however, these countries might be shifting to CO₂ systems once it become commercially available. On the other hand, it will gain more and more share in North America, once it become available, because it is easy to shift from HFC-134a (USEPA, 2006b).

Limitations: Although the flammability of HFC-152a is less than hydrocarbons, safety systems would still be necessary; personnel training would also be needed (USEPA, 2006b).

Sources of Information:

- 1. Baker, J.A. (1998) "Mobile Air Conditioning and Global Warming". *Proc. Phoenix Alternate Refrigerant Forum 1998*, Suntest Engineering, Scottsdale, AZ.
- 2. California Air Resources Board (2004) "Staff report: Initial Statement of Reasons for Proposed Rulemaking, Public Hearing to Consider Adoption of Regulations to Control Greenhouse Emissions from Motor Vehicles", California Air Resources Board, August 6, 2004.

- 3. California Energy Commission (2005) "Emission Reduction Opportunities for Non-CO₂ Greenhouse Gases in California", a report prepared by ICF Consulting for California Energy Commissions, CEC-500-2005-121, July 2005.
- 4. California Energy Commission (2006) "Inventory of California Greenhouse Gas Emissions and Sinks: 1990 to 2004", final staff report, December 22, 2006.
- 5. Fisher, S.K.; Tomlinson, J.J.; Hughes, P.J. (1994) "Automobile Air Conditioning: Energy and Global Warming Impacts of Not-in-kind and Next Generation CFC and HCFC Alternatives", prepared by Oak Ridge National Laboratory for Alternative Fluorocarbons Environmental Acceptability Study and U.S. Department of Energy, Oak Ridge, TN.
- 6. International Energy Agency (2003) "Building the Cost Curves for the Industrial Sources of Non-CO₂ Greenhouse Gases", Report Number PH4/25, IEA Greenhouse Gas R&D Programme, Cheltenham, United Kingdom, October 2003.
- 7. Mathur, G.D. (1996) "Performance of Vapor Compression Refrigeration System with Hydrocarbons: Propane, Isobutane, and 50/50 Mixture of Propane/isobutane", *Proc. International Conference on Ozone Protection Technologies*, October 21-23, Washington, D.C.
- 8. Paul, J. (1996) "A Fresh Look at Hydrocarbon Refrigeration: Experience and Outlook", *Proc. International Conference on Ozone Protection Technologies*, October 21-23, Washington, D.C.
- 9. Sand, J.R.; Fischer, S.K.; Baxter, V.D. (1997) "Energy and Global Warming Impacts of HFC Refrigerants and Emerging Technologies". Prepared by Oak Ridge National Laboratory for Alternative Fluorocarbons Environmental Acceptability Study and U.S. Department of Energy, Oak Ridge, TN.
- 10. U.S. Climate Technology Program (2005) "Technology Options for the Near and Long Term", U.S. Department of Energy, http://www.climatetechnology.gov/index.htm, August 2005.
- 11. U.S. Environmental Protection Agency (2001) "U.S. High GWP Gas Emissions 1990–2010: Inventories, Projections, and Opportunities", Office of Air and Radiation, U.S. Environmental Protection Agency, EPA 000-F-97-000, June 2001.
- 12. U.S. Environmental Protection Agency (2004) "Analysis of Cost to Abate Ozone-depleting Substitute Emissions", Office of Air and Radiation, U.S. Environmental Protection Agency, EPA 430-R-04-006, June 2004.
- 13. U.S. Environmental Protection Agency (2006a) "Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990 to 2004" Office of Atmospheric Programs, United States Environmental Protection Agency, EPA-430-R-06-002, June 2006
- 14. U.S. Environmental Protection Agency (2006b) "Global Mitigation of Non-CO₂ Greenhouse Gas Emissions and Sinks: 1990 to 2004" Office of Atmospheric Programs, United States Environmental Protection Agency, EPA-430-R-06-005, June 2006.
- 15. van Gerwen, R.; Vervoerd, M. (2000) "Emission reduction of non-CO₂ Greenhouse Gases Used as Refrigerants" in Non-CO₂ Greenhouse Gases: Scientific Understanding, Control and Implementation (edited by J. Van Ham *et al.*), Kluwer Academic Publishers, London.
- 16. Walker, D. (2000) "Low-charge Refrigeration for Supermarkets", IEA Heat Pump Center Newsletter, vol. 18, no. 1, p. 13-16.
- 17. Wertenbach, J.; Maue, J.; Volz, W. (1996) "CO₂ Refrigeration System in Automobile Air Conditioning", *Proc. International Conference on Ozone Protection Technologies*, October 21-23, Washington, D.C.